

SPCC COMPLIANCE REPORT

DATE January 21, 1981 TIME 1400 NPDES PERMIT NO. OK0001643NAME OF FACILITY Fansteel Metals TYPE OF FACILITYLOCATION Muskogee, Muskogee County, Oklahoma 74401NAME OF INDIVIDUAL OWNER AND/OR OPERATOR RESPONSIBLE FOR FACILITY, MAILING
ADDRESS, AND TELEPHONE NUMBER. James A. Pierret
Number 10, Tantalum Place
(918) 689-6303 Muskogee, Ok 74401TYPES OF OIL STORED AND CAPACITY OF ABOVE GROUND AND BURIED STORAGE.
Above ground storage of an out-of-service PCB Transformer - 760 gallons

IS A CERTIFIED SPCC PLAN AVAILABLE FOR INSPECTION () YES (X) NO

CERTIFYING ENGINEER: NAMESTATE REGISTRATION NO.DATE SPCC PLAN CERTIFIEDIS SPCC PLAN FULLY IMPLEMENTED? (ARE THE ITEMS CALLED FOR IN THE PLAN IN THE
INTEREST OF SPILL PREVENTION ACTUALLY INSTALLED- IF OBSERVABLE?)No plan but a dike has been constructed around the transformerNAME OF WATER BODY THAT POTENTIAL SPILL COULD ENTER: OR IF UNNAMED TRIBUTARY,
THEN FIRST NAMED WATERBODY DOWNSTREAM Arkansas RiverCOMMENTS: Recommend that a SPCC be required for this facilityNAME OF INVESTIGATOR J. J. Black OKLAHOMA WATER RESOURCES BOARDDATE: 3 - 12 - 81